

**MINUTES
CITY COMMISSION SPECIAL MEETING
CITY HALL, 701 WASHINGTON**

Monday, April 10, 2015 3:00 p.m.

The governing body met in special call meeting on April 10, 2015, at 3:00 p.m. in the City Commission Room at City Hall, with the following members being present: Commissioners Wentz, Parker, Johnson, Pounds, and Hasch.

Absent: None.

Other Officers: City Manager Uri and City Clerk Crum.

Visitors: Jeremy Arnold, Chuck Lambertz, Ken Johnson, Toby Nosker, Jessica LeDuc.

**CALL FOR SPECIAL CITY COMMISSION MEETING
CITY OF CONCORDIA, KANSAS**

TO THE BOARD OF CITY COMMISSIONERS:

Special meeting of the Board of Commissioners is hereby called to be held as follows:

Place: City Commission Room, Concordia, Kansas
Date: April 10, 2015
Time: 3:00 o'clock P.M

The object of said meeting will be as follows:

1. Call to Order
2. Sewer Line Repair
3. Adjournment

LYLE L. POUNDS
COMMISSIONER

TIMOTHY S. PARKER
COMMISSIONER

CHARLES B. JOHNSON
COMMISSIONER

S. CHRISTY HASCH
COMMISSIONER

MARSHA L. WENTZ
COMMISSIONER

RETURN OF SERVICE

The undersigned received the original notice via email of the Special City Commission meeting, at 3:38 o'clock p.m., April 8, 2015.

1. Served the same personally on Lyle Pounds. /s/ Stacey Crum.
2. Served the same personally on Tim Parker. /s/ Stacey Crum.
3. Served the same personally on Charles Johnson. /s/ Stacey Crum.
4. Served the same personally on Christy Hasch. /s/ Stacey Crum.
5. Served the same personally on Marsha Wentz. /s/ Stacey Crum.

SEWER LINE REPAIR

City Manager Uri explained that, while investigating issues with the lift station, a leak was found in the sewer line running under the river to the north development. It has been determined that the gas line was laid over the top of the sewer line, rather than parallel to it, at the point of leakage, though at this point it cannot be determined if that is the reason the line failed. Service to the line has stopped, and the crew is hauling sewage twice a day. The crew also cleaned up the seepage, which was on a sand bar in the middle of the riverbed. Though it's impossible to say how long it has been leaking, a Google Earth photo taken in May of 2014 showed the hole where sewage has been coming up.


The recommendation was to replace the line immediately, before determining, if possible, who is responsible. It has been estimated that it will cost \$65,000.00 to replace the entire line under the river. Campbell & Johnson would monitor the work for \$90.00 per hour, up to \$5,000.00.

Commissioner Parker moved to contract with M & D Excavating for \$65,000.00 to install the sewer line under the river and \$5,000.00 for Campbell & Johnson to oversee the project. Commissioner Johnson seconded. Motion carried unanimously.

ADJOURN

There being no further business, it was moved and seconded to adjourn. The meeting adjourned at 3:25 p.m.

(Seal)



Stacey Crum
City Clerk